



New Jersey Department of Health
 Environmental and Chemical Laboratory Services
 PO Box 361, Trenton, NJ 08625-0361
 NJDEP Lab ID#: 11036
 EPA Lab ID#: NJ01351

Client Address:
 Delaware Valley School for Exceptional Children
 87 Pearson Dr.
 Hamilton NJ, 08610

Report Date: 07/01/2025 13:46
 Project: Drinking Water Lead and Copper Testing

Client Sample ID: **Kitchen Sink**
 Sample Location:
 Field ID No: Kitchen Sink
 Sample Type: First Draw

Lab Number: 25F1601-01
 Sampled: 6/12/2025 7:40:00AM
 Received: 6/16/2025 11:29:00AM

Analyte	Result	Qualifier	Method Detection Limit	Reporting Limit	Units	Prepared	Analyzed	Method
Metals by EPA 200 Series Methods								
Copper	0.886		0.158	0.500	ug/L	06/27/2025	06/27/2025 12:30	EPA 200.8
Lead	K		0.075	1.00	ug/L	06/27/2025	06/27/2025 12:30	EPA 200.8

Notes and definitions:

JR Approximate value. Result is below the reporting level but greater than the method detection limit.

Case Narrative Section:

NJDOH PHEL

Dave Riker, Organic Testing Laboratory Supervisor

Doug Haltmeier, Inorganic Testing Laboratory Supervisor